



Main Components	
1	51mm Korok Panel
	51mm thick Korok panel wall. Comprises aerated concrete core at nominally 600kg/m ³ density. The galvanised steel skin is nominally 0.4mm thick BMT (0.44mm TMT). The penetration hole size to be cut out is Ø13mm
2	Promat PROMASEAL A Fire rated sealant
	75mm (wide) x 35mm deep cone between the service and the wall penetration. Applied to both sides of the wall.
3	2.5mm TPS (2 core plus earth power cable)
	Outside diameter 4mm.
4	Annular Gap
	Annular gap between Flexiwrap and Korok aperture is as close to 1mm all around the cable.