



Main Components	
1	51mm Korok Panel
	51mm thick Korok panel wall. Comprises aerated concrete core at nominally 600kg/m ³ density. The galvanised steel skin is nominally 0.4mm thick BMT (0.44mm TMT). The penetration hole size to be cut out is Ø13mm
2	Promat PROMASEAL A Fire rated sealant
	70mm (wide) x 30mm deep cone between the service and the wall penetration. Applied to both sides of the wall.
3	3 x CAT 6 data cables
	Outside diameter 6mm (each cable).
4	Annular Gap
	Annular gap between cables and Korok aperture is no greater than 3mm all around the cables.