

KOROK® 51mm panels.
Comprises aerated concrete core at nominally 600kg/m³ density. The galvanised steel skin is nominally 0.4mm thick BMT (0.44mm TMT)

Promat Promaseal A Fire rated sealant. 35mm x 35mm fillet between the FCW40 collar and the wall. Applied to both sides of the wall. The 5mm annular gap between the Korok wall aperture and the FCW40 collar is filled with the same fire rated sealant

Promat FCW40 collar internally fitted with equal lengths protruding from the wall. See Promat documentation for specific dimensions

The penetration hole size to be drilled is 88Ø

40mm uPVC pipe. Inside diameter of the pipe is 40mm

Annular gap between collar and Korok aperture is no greater than 5mm all around. The service and collar is fitted centrally



KOROK® Panel

Korok® 51mm Panel

Wall Penetration 40mm uPVC pipe


File: korok_pene.rvt

Issue: 1.0 Date: Feb 2019

Scale: 1 : 2

Reference

KOROK_PENE_51080



Horizontal
&
Vertical