

FS4 - 240MIN FIRE RATED SYSTEM (KWR4)

SPEC. CODE	STC	FRR	WALL THICKNESS*	FRAME	CAVITY	SYSTEM SUMMARY
FS4	55	-/240/240	206 mm	N/A	50 mm between panels minimum	2 parallel walls made up of KOROK® 78 mm panels with a 50 mm cavity. No linings.

*Nominal thickness

KOROK® PANEL

KOROK® panels are 78 mm thick, located in KOROK® C-track 60mm high x 80 mm wide x 1.15B.M.T. C-track is fixed at a maximum of 400 mm centres bedded on a bead of fire-rated sealant.

SEALANT

Beads of fire rated sealant are required around the perimeter of the KOROK® system. Refer to the installation section of this publication for more information on sealant application, and to the KOROK® Components Summary for approved sealants.

